

Test Report No. 1368/2

Date Issued: 15 December, 2005

ITACS

High Power Testing

International Testing and

Certification Services Pty. Ltd.

ABN 60 098 886 563

27 Sheehan Road

PO Box 5140,

Heidelberg West DC,

Victoria 3081

Telephone (03) 9458 3988

International + 61 3 9458 3988

Fax (03) 9458 3172

E-Mail itacs@itacslab.com

Product: Horizontal mounted main copper busbars
4 bars of 100mm x 6.3mm with 5 supports of
"Modular main switchboard Form 4
63kA/1sec & 80kA/1sec 2500A, 3000A &
3500A type."

Clients rating: 415V, 50Hz
Rated short-time current
(I_{cw}) = 80kA, 1.0s

Client: Price Trandos
Engineering Pty Ltd
11 Agett Road
Malaga W.A. 6090
Australia

Nature of tests: Verification of short-circuit withstand
strength of the main busbars according to
Clause 8.2.3.2.3 b) of AS/NZS
3439.1:2002 "Low-voltage switchgear
and controlgear assemblies
Part 1: Type-tested and partially type-
tested assemblies"

Results: The Product withstood the tests, refer results here.

Prepared by:



John Strugarek

NATA Approved Signatory:



Antony K. Milovac



NATA ACCREDITED LABORATORY NO. 1149
The tests, calibrations or measurements covered by
this document have been performed in accordance
with NATA requirements which include the
requirements of ISO/IEC 17025 and are traceable to
national standards of measurement. This document
shall not be reproduced, except in full.

ITACS